

Analysis of wastewater 2008 - 2018

Test no	Year	Month	Original- / Risit test	(6,5 - 9,0) pH	Temp.	Max 300	Max 500	Max 1000	Max 0,3	Max 0,25	Max 0,5	Max 10	Max 23m	Comments
						Sus.stof	Sulphate	Chloride	Chrome	Nickel	Copper	Mineral oil	Water/day	
3.1	2008	July	Original	7,53	20,4	900	35	94	1,3	1,100			2,2	
4.1	2008	Oct	Original	7,14	17,5	45	26	190	0,028	0,198			2,0	
4.2	2008	Nov	Original	8,07	15,20	18	67	< 0,5	0,009	0,026			10,0	
1.1	2009	Maj	Original	8,04	16,4	20	32	320	0,004	0,735			1,3	
2.1	2009	Jul	Original	7,85	22,0	19	52	172	0,012	0,507			110,0	Messurement of water, not correct !
3.1	2009	Aug	Original	8,18	19,8	38	34	250	< 0,002	0,353			295,0	Messurement of water, not correct !
4.1	2009	Aug	Original	8,99	15,3	39	40	310	< 0,002	0,174			13,5	
1.1	2010	Mar	Original	8,67	15,0	1200	40	460	0,916	0,265			14,0	
1.2	2010	Apr	Risit test	6,00					< 0,002	0,108				
2.1	2010	Jun	Original	8,44	21,80	380	52	440	0,072	0,060			4,5	
3.1	2010	Sep	Original	7,50	21,0	61	34	79	0,093	0,162			2,7	
4.1	2010	Dec	Original	8,35	14,2	28	33	104	0,018	0,053			6,7	
4.2	2011	Dec	Risit test	7,80	14,4				2,09	1,190			6,0	
4.1	2011	Dec	Original	4,87	15,7	110	41	56	6,64	5,720			12,0	
3.1	2011	Sep	Original	8,37	18,0	110	41	160	0,198	0,134	0,434	19,0	10,0	
2.1	2011	Jun	Original	8,46	20,0	12	37	208	< 0,002	0,013	0,020	1,3	9,0	
1.2	2011	Apr	Risit test	7,65	17,0	1000	22	14	0,248	0,120			7,0	
1.1	2011	Mar	Original	7,48	11,7	2220	30	495	1,74	0,995			9,2	
4.3	2012	Jan	Risti test	7,30	13,2				0,004	0,029			25,0	
1.2	2012	Mar	Original	8,20	14,1	400	30	550	0,285	0,156			18,0	The local Government didn't want a risit test
2.1	2012	Jul	Original	8,06	20,0	13	43	440	0,006	0,111	0,260	1,9	14,0	
3.1	2012	Sep	Original	7,81	19,0	11	33	350	0,008	0,060	0,004	2,3	4,7	
4.1	2012	Nov	Original	7,81	17,0	42	34	375	0,04	0,030	0,382	4,8	6,0	
1.1	2013	Feb	Original	8,22	11,7	810	29	410	0,088	0,069			33,0	
2.1	2013	Apr	Original	8,22	15,5	1500	27	510	3,59	2,000	3,110	89,0	9,0	defective solenoid valve
3.1	2013	Aug	Original	8,03	20,0	940	26	450	0,202	0,115	0,559	92,0	28,0	Emptying of the pressure tank
3.2	2013	Sep	Risit test	7,47	3,0	120					0,816	14,0	30,0	
1.4	2013	Nov	Original	8,25	16,4	840	33	420	1,22	0,654	1,020	74,0	23,0	
1.1	2014	Mar	Original	7,77	12,0	160	48	100	0,707	0,490			41,0	
2.1	2014	Apr	Original	11,99	16,0	450	110	96	< 0,002	0,005	0,041	12,0	20,0	
3.1	2014	Sep	Original	8,27	21,0	76	38	155	0,077	0,527			14,0	
3.2	2014	Sep	Risit test	8,68	20,0					0,303			29,0	
4.1	2014	Dec	Original	8,50	15,0	280	50	58	1,07	0,560	0,378	56,0	2,1	
1.1	2015	Mar	Original	10,16	13,0	500	49	109	0,51	0,303	0,313	63,0	23,0	
2.1	2015	May	Original	7,20	17,6	63	48	185	0,266	0,410			19,9	
3.1	2015	Oct	Original	8,93	13,4	54	51	200	0,016	0,017	0,029	3,6	3,6	
4.1	2015	Dec	Original	8,84	13,7	14	38	410	0,002	0,006			16,8	
1.1	2016	Apr	Original	8,17	14,7	26	46	150	0,028	0,145	0,013	1,0	15,0	
2.1	2016	Juni	Original	8,42	30,4	176	44	37	0,537	0,283			5,6	
2.2	2016	Juli	Risit test	7,92	21,0	51	42	75	0,217	0,198			8,5	
3.1	2016	Nov	Original	6,79	14,4	95	43	109	0,455	0,673	0,055	4,5	3,5	
3.2	2016	Dec	Risit test	6,49	14,0				< 0,002	< 0,002			12,0	
4.1	2016	Dec	Original	8,12	14,1	21	38	152	0,018	0,056			7,7	
1.1	2017	Feb	Original	9,26	16,1	24	50	249	< 0,002	< 0,002	0,013	1,9	13,0	Has not triggered a NCR - Authorities are informed
2.1	2017	Maj	Original	7,84	7,2	92	46	136	0,125	0,688			5,9	NCR - Authorities are informed
2.2	2017	Maj	Risit test	8,31	18,5					0,922			19,0	Service of the facility - Authorities are informed
3.1	2017	Oct	Original	8,66	19,4	25	46	157	0,037	0,048	0,016	1,9	8,5	
4.1	2017	Dec	Original	8,70	11,5	324	47	307	0,198	0,108			2,5	Authorities are informed - wait and see the result of the next analysis
1.1	2018	Mar	Original	8,59	15,1	157	81	154	0,357	0,223	0,157	1,3	10,0	
2.1	2018	Maj	Original	8,08	23,0	55	46	314	0,007	0,007			25,0	The amount of water is too heigh but has not been reg. af a NCR
3.1	2018	Aug	Original	8,36	21,0	99	47	194	0,065	0,031	0,032	1,3	59,0	The amount of water is too heigh but has not been reg. af a NCR